



# DART D2 Preliminary Ventilation Report

DART GPC6

DRAFT, Issued for DART Review  
Dallas, Texas  
October 12, 2020



This Report was Prepared for DART Review and Comment  
General Planning Consultant Six Managed by HDR



## Document Revision Record

<b>DART D2 Draft Ventilation Report</b>		<b>HDR Report Number:</b> Click here to enter text.	
<b>Project Manager:</b> Andy Stone		<b>PIC:</b> Click here to enter text.	
<b>Revision Number:</b> 0		<b>Date:</b> February 28, 2020	
<i>Version 1</i>		<i>Date: October 12, 2020</i>	
<i>Version 2</i>		<i>Date: Click here to enter text.</i>	
<b>Originator</b>			
<b>Name:</b> Jerry Casey, Triet Tran, Suraj Parayil, Yunlong Liu		<b>Firm:</b> HNTB Corporation	
<b>Title:</b> Draft Ventilation Report		<b>Date:</b> 10.12.2020	
<b>Commenters</b>			
<b>Name:</b> Sean Cassady <b>Firm:</b> HNTB Corp <b>Date:</b> 10/8/20	<b>Name:</b> Click here to enter text. <b>Firm:</b> Click here to enter text. <b>Date:</b> Click here to enter text.	<b>Name:</b> Click here to enter text. <b>Firm:</b> Click here to enter text. <b>Date:</b> Click here to enter text.	
<b>Name:</b> Click here to enter text. <b>Firm:</b> Click here to enter text. <b>Date:</b> Click here to enter text.	<b>Name:</b> Click here to enter text. <b>Firm:</b> Click here to enter text. <b>Date:</b> Click here to enter text.	<b>Name:</b> Click here to enter text. <b>Firm:</b> Click here to enter text. <b>Date:</b> Click here to enter text.	



Approval	
<b>Task Manager:</b> Sanja Zlatanic	<b>Date:</b> Click here to enter text.
<b>Verified/Approved By:</b> Click here to enter text.	<b>Date:</b> Click here to enter text.

Distribution		
<b>Name:</b> Click here to enter text.	<b>Title:</b> Click here to enter text.	<b>Firm:</b> Click here to enter text.
<b>Name:</b> Click here to enter text.	<b>Title:</b> Click here to enter text.	<b>Firm:</b> Click here to enter text.

## Contents

1	Introduction .....	5
1.1	General.....	5
1.2	Project Description .....	5
1.3	Applicable Codes, Standards and Requirements .....	6
2	Station Ventilation Concept .....	8
2.1	Design Objective .....	8
2.2	Design Principle .....	8
2.3	Smoke control and ventilation strategy .....	9
2.3.1	Fire Scenario (a) Train fire OTE and OPE on: .....	9
2.3.2	Fire Scenario (b) Track fire: .....	9
2.3.3	Fire Scenario (c) Platform fire: .....	10
2.4	Ventilation airflow diagram .....	11
2.5	Ventilation Plant Schematic .....	13
3	Methodology and Analysis .....	14
3.1	Design Methodology.....	14
3.2	Inputs and Assumptions .....	15
3.2.1	Design Fire Scenario.....	16
3.2.2	SES Inputs .....	18
3.2.3	CFD Input.....	18
4	Results and Discussion .....	21
4.1	SES Results .....	21
4.2	CFD .....	27
4.2.1	Case No.3 .....	28



## Tables

Table 1 Fire Life Safety Concept Design Principles Code Matrix .....	6
Table 2: Fire Scenarios .....	9
Table 3: SES K Factors.....	18
Table 4: Ventilation flow parameters used in CFD (kcfm) scenario a, b and c.....	19
Table 5: SES Simulations .....	22
Table 6: CFD Results .....	28

## Figures

Figure 1. Layout indicating approximate extents of DART D2 Subway alignment .....	5
Figure 2: Fire Scenario (a) .....	9
Figure 3: Fire Scenario (b) .....	10
Figure 4: Fire Scenario (c) .....	10
Figure 5: Fire Scenario Option 1 .....	11
Figure 6: Fire Scenario Option 2 .....	12
Figure 7: Commerce Station Ventilation Schematic .....	13
Figure 8: Mode Matrix Diagram .....	14
Figure 9: Fire Growth Rate.....	17
Figure 10: CFD Model.....	19
Figure 11: CFD Train .....	20
Figure 12: Geometry Simplification.....	21
Figure 13: SES Case No. 3r2 Diagram.....	23
Figure 14: SES Case No. 4 Diagram .....	23
Figure 15: SES Case No. 5 Diagram .....	24
Figure 16: SES Case No. 6 Diagram .....	23
Figure 17: SES Case No. 7 Diagram .....	23
Figure 18: SES Case No. 10 Diagram .....	23
Figure 19: SES Case No. 11r1 Diagram.....	23
Figure 20: SES Case No. 9 Diagram .....	23
Figure 21: SES Case No. 12 Node Network.....	27
Figure 22: SES Case No. 12 Pressure Change graph .....	27
Figure 23: CFD Case No.3r2 Smoke Visibility .....	29
Figure 24: CFD Case No.4 Smoke Visibility .....	29
Figure 25: CFD Case No.5 Smoke Visibility .....	30

## Appendices





## Acronyms and Abbreviations

AHJ	Authority Having Jurisdiction
DART	Dallas Area Rapid Transit
DCM	Design Criteria Manual
DFT	Dry Film Thickness
FCC	Fire Command Center
FDC	Fire Department Connection
FPM	Feet Per Minute (velocity)
FT	Feet (Length)
GPM	Gallons Per Minute (Flow)
In w.g.	Inches of Water Gauge (pressure)
LRV	Light Rail Vehicle
NFPA	National Fire Protection Association
SLRV	Super Light Rail Vehicle
SF	Square Feet (Area)
TXDOT	Texas State Department of Transportation
MCE	Metro Center East
MCW	Metro Center West
CSE	Commerce Street East
CSW	Commerce Street West
CBE	CBD East
CBW	CBD East

# 1 Introduction

## 1.1 General


The preliminary ventilation report provides presents the evaluation of emergency ventilation within the underground portion of the DART D2 Subway extension. The Authority Having Jurisdiction is the Texas State Department of Transportation (TxDOT). This report will address the fire life safety systems in place for the underground trainway and station portion of the DART D2 Subway project.


This conceptual 30% design preliminary fire life safety ventilation report is preliminary and conceptual in nature and has not been signed or sealed. Tunnel ventilation system capacities and configuration is dependent on geometric configuration of station and headhouse elements including smoke rated enclosures at concourse and smoke control baffle downstands at platform and concourse locations. It is the Design-Builders responsibility to complete the design and prepare a ventilation report based on their design. The Design-Builder shall conduct all Work necessary to design, furnish, and install an integrated and fully functional fire life safety system. The Design-Builder shall provide and submit for review and comment an engineering analysis of all life safety systems, including but are not limited to the following: Fire hazard analysis, Ventilation analysis, Egress analysis, and Fire durability analysis. These analyses shall be based on the Design-Builder's proposed design and installation to confirm compliance with the National Fire Protection Association (NFPA) 130 standards for fixed guideway transit and passenger rail system as well as other applicable standards. These analyses shall be prepared by the Design Builders Engineer of Record who must be qualified in this area of practice as an active licensed professional engineer in the State of Texas.

## 1.2 Project Description

The DART D2 Subway Project is comprised of a subway system that would begin southeast of Victory Station and end west of Baylor University Medical Center Station. The subway extension will include one at-grade station (Museum Way), and three underground Rail stations (Metro Center, Commerce Street, and CBD East).

**Figure 1. Layout indicating approximate extents of DART D2 Subway alignment**





Ventilation systems will need to be considered for the underground segment of the DART D2 Subway system to help with exhaust during normal train operations, as well as during a fire emergency to limit smoke spread and fire hazard development.

## 1.3 Applicable Codes, Standards and Requirements

The following standards are applicable for the Fire Life Safety Analysis for the DART D2 Subway:

1. International Building Code (IBC) as amended by the City of Dallas
2. International Fire Code (IFC) as amended by the City of Dallas
3. NFPA 130 2014 edition – Standard for Fixed Guideway Transit and Passenger Rail Systems
4. DART, Emergency Operating Procedure, Publication Number: 101.01, 04/01/2004
5. DART, Fire Smoke (Tunnel) Operating Procedure, Publication Number: 101.07, 04/01/2004

In addition to the standards listed above the DART Design Criteria Manual (DCM) 2003 edition by ACT 21 is used to evaluate any applicable design features, but note that the DCM is project specific and does not directly apply to the current DART D2 Project

**Table 1 Fire Life Safety Concept Design Principles Code Matrix**

Design Feature	Code/Standard Basis	Discussion
Fire Rated Construction	2014 NFPA 130; 5.2.4.1	Interconnection between floor levels is allowed with special provisions.
Fire Rated Construction	2014 NFPA 130; 5.2.4.3	Fire Rated separation between ancillary occupancies as required by NFPA 101
Fire Rated Construction	2014 NFPA 130; 5.2.4.2	All Public areas shall be fire separated from adjacent non-public areas
Corridor Width	2015 IBC; 1020.2 2014 NFPA 130; 5.3.4.2	Minimum corridor width 44 in. Additionally applies to platforms from NFPA 130



Stairway width	2015 IBC; 1011.2	Minimum stairway width 44 in.
Number of exits	2015 IBC; 1006.2.1.1	Three exits or exit access doorways shall be provided from any space with occupant load of 501 to 1000
Definition of Point of Safety	2014 NFPA 130; 3.3.35	Special provisions allow point of safety at the following: trainway, station, at grade point beyond vehicle
Evacuation	2014 NFPA 130; 5.3.1.1 2014 NFPA 130; 5.3.1.2	Platform Evacuation Time – Evacuate platform in 4 minutes or less  Evacuation Time to a Point of Safety in 6 minutes or less
Exits	2014 NFPA 130; 6.3.1.4	Maximum distance between exits shall not exceed 2500 ft
Cross Passage	2014 NFPA 130; 6.3.1.6	Cross-passageways shall not be farther than 800 ft
Exit Signs	2014 NFPA 130; 6.3.5.5	Enclosed trainways greater than 1 train length shall be provided with directional signs as appropriate for emergency procedures
Mechanical Ventilation	2014 NFPA 130; 7.1.2.2 2014 NFPA 130; 7.2.3	Mechanical Ventilation required at: 1. Enclosed Stations 2. Trainway greater than 1000 ft Design should incorporate: 1. Fire Heat release rate 2. Fire Growth rate 3. Station and trainway geometries 4. Elevation, temperature differences wind etc.
Fan ramp up time	2014 NFPA 130; 7.3.1.1	Fan motors designed to achieve full operating speed in no more than 30 seconds from stopped position, and no more than 60 seconds for variable-speed motors.
Standpipe	2014 NFPA 130; 5.4.5 2014 NFPA 130; 5.4.5.2	Class I standpipes shall be installed in enclosed stations in accordance with NFPA 14  Standpipes are required to be enclosed in fire rated construction unless: 1. System is cross-connected or fed from two locations. 2. Isolation valves are installed not more than 800 ft apart
Hydrants	2003 DART DCM Vol 1 by ACT 21; 29.6.1	Hydrants within 150 feet of Fire Department Connection to a Standpipe system





		Within 150 feet of each subway station entrance or access point.
Hydrants	2015 IFC; 507.5.1.1	Standpipe system shall have a fire hydrant within 100 feet of the fire department connections.
Ventilation Requirements	2003 DART DCM Vol 1 by ACT 21; 25.3.2	Maintain a single Evacuation path from the train that is clear of smoke and hot gases.
Ventilation Requirements	2003 DART DCM Vol 1 by ACT 21; 25.4.5	<p>Tunnel Ventilation Fan Dampers: Max velocity 1800 FPM</p> <p>Tunnel Ventilation Fan Sound Attenuators: Max velocity 1800 FPM</p> <p>Isolation Dampers: Max velocity 2000 FPM</p> <p>Concrete Ducts/Plenums/Shfts:</p> <p>Tunnel Ventilation Shaft: Nominal velocity of 1800 FPM, Max velocity of 2200 FPM</p> <p>Other concrete ducts/plenums/shfts: Nominal velocity of 1500 fpm, Max velocity of 1800 FPM</p>

## 2 Station Ventilation Concept

### 2.1 Design Objective

The objective of the ventilation and fire safety design is to mitigate hazards to provide adequate level of safety for tunnel or station area occupants during periods of revenue and maintenance operations. Ventilation system configuration and sequence of operations are established to provide tenable environment to facilitate self-evacuation from tunnel and station areas.

### 2.2 Design Principle

Stations of the subject project has been proposed with platform screen doors (PSD), which separate the platform and the trackway into two zones. Therefore trackway fires and platform fires are managed separately. Moreover, it can also achieve energy savings for climate control, as the station cooling air will not be lost into the tunnel as it is separated from the platform of the station.


## 2.3 Smoke control and ventilation strategy

**Table 2: Fire Scenarios**

ID	Fire Location	Fire HRR	Smoke control strategy
(a)	Train fire	14.9 MW (Medium growth rate)	Over Track Exhaust (OTE) Over Platform Exhaust (OPE)
(b)	Trackway Fire	1.5 MW (UF)	OTE
(c)	Platform Fire	3.5 MW (UF)	OPE

### 2.3.1 Fire Scenario (a) Train fire OTE and OPE on:


During a train fire the over track exhaust (OTE) dampers will open to exhaust the smoke from the incident track. The platform screen doors are open to allow passengers to exit the train. Since the doors are open there is a concern that smoke will develop in the platform as well. So platform exhaust dampers are opened as well to help with the exhaust of smoke.



**Figure 2: Fire Scenario (a)**

### 2.3.2 Fire Scenario (b) Track fire:


Trackway fire is non-rolling Stock fires occurring in the trackway within the Station length. For such an incident – where a train is not located within the incident station trackway – the PSDs on the incident track remain open representing a worst case scenario and the incident track OTE will be operated in smoke control mode, exhausting 127 kCFM, as shown in Figure 3.



**Figure 3: Fire Scenario (b)**

### 2.3.3 Fire Scenario (c) Platform fire:

For a station fire originating within a platform zone, the objective will be to limit smoke to the incident zone. On activation, the Station Smoke Management System (SSMS) will utilize the OTE fans to exhaust through the duct above the platform to provide over platform exhaust as shown in Figure 4.




**Figure 4: Fire Scenario (c)**


## 2.4 Ventilation airflow diagram

Ventilation airflow diagrams for two options are presented for fire scenarios (a) (b) (c) in Figure 5 and Figure 6.

(a)



(b)



(c)




Figure 5: Fire Scenario Option 1







Figure 6: Fire Scenario Option 2

## 2.5 Ventilation Plant Schematic

The preliminary ventilation plant layout includes a set of 3 fans per fan plant, each with a capacity of 250 kCFM. It is assumed that a maximum capacity of 500 kCFM will be required at each fan plant location. This results in a maximum of 2 fans on at a time with and an additional fan on standby for redundancy. Figure 7 demonstrates the ventilation configuration for Commerce Station.



**Figure 7: Commerce Station Ventilation Schematic**

The ventilation fans have been preliminarily sized for 250 kCFM at 3.6 in w.g. this corresponds to a 400 hp fan. See Appendix A for preliminary fan pressure calculation. Calculations were based on preliminary assumptions for duct and plenum sizes in order to provide adequate ventilation.

Fires can occur at multiple locations along the Dart D2 Extension. Providing adequate ventilation for different fire scenarios can prove to be challenging because of the different components that need to be configured, such as damper opening positions, which fans to turn on, and whether the fans are in supply or exhaust mode. For this reason, a preliminary mode matrix is created to establish the different configurations that will be implemented within different fire zones along the length of the alignment. Figure 8 shows a preliminary layout of the different equipment involved for emergency ventilation.




Figure 8: Mode Matrix Diagram

## 3 Methodology and Analysis

### 3.1 Design Methodology

Tunnel ventilation design for the project will be configured to manage environmental conditions within the enclosed underground trainways and public circulation areas for normal, congested and emergency fire scenario conditions. Conceptual space proofing requirements will be established by emergency fire scenarios for tunnel and station fires. A segment wide ventilation flow network model created with the SES (Subway Environmental Simulation) tool is created for the underground portion of the Dart D2 extension. A series of SES simulations are developed to test the different fire scenarios and establish



flow rates. A 3D model of the station is created and set up to run scenarios aligned with SES cases, using results from SES as boundary conditions. The methodology applied for this analysis is broken into the following steps:

1. **Gather data:** Gather geometrical data, walkway tunnels/stairs, platforms, and ventilation shafts.
2. **Evaluation & Simplification of Geometry:** Evaluate detail of features such as signages, beams, and other projections in space to determine if they introduce significant impacts on ventilation flow conditions generated by a fire in the station.
3. **Establish domain:** Determine fire and airflow region for proper model domain. Use ancillary calculations as needed to validate an adequate model size prior to solid modeling.
4. **Solidify model:** Create a three-dimensional computer solid model of station features determined to be of significance to ventilation flow field.
5. **Meshing:** Evaluate the solid model for decomposition and meshing schemes. Generate the Mesh model.
6. **Solve:** Read mesh into Fluent software solver and prepare inputs for iterative solution scheme including boundary conditions, model equations, solver schemes, and other customized time-dependent inputs. A detailed discussion of model inputs for fire source term is included in Section 3.2.1, of this report.
7. **Simulation:** Initiate iterative solution based on assumed time step interval for managing stable transient solution.
8. **Monitor:** Checkpoint simulation with the following activities: monitor residual values generated by momentum, continuity and energy equations of the simulation, evaluate wall function metrics generated for dataset at intermediate time steps, evaluate flow velocity conditions verses cell dimensions to confirm flow transit criterion is maintained, review simulation inputs for any incorrect boundary condition settings. Reconfigure simulation and restart if any issues are discovered.
9. **Verify:** Verify simulation is complete.
10. **Post process:** Post process simulation to show smoke visibility conditions or other parameters that are of interest
11. **Analyze:** Analyze results for compliance with intended scope and pertinent code requirements
12. **Repeat:** Repeat steps 3 through 11 as needed for subsequent simulations, such as varying fire location(s), ventilation modes, or other environmental characteristics to accurately represent project conditions and goals

Key features and project dimensions of the overall facility for this analysis were developed from the architectural drawings. Simplifications for details not relevant to the solution were made and applied to the CFD model to help reduce computational time. The engineering team analyzed the fire scenarios then applied them to the 3D constructed model along with ambient characteristics. Results gathered from the CFD analysis allowed the engineering team to verify if the proposed ventilation meets the project criterion for safe egress.

## 3.2 Inputs and Assumptions

Makeup airflow from emergency ventilation operations comes from headhouses above, this assumes that public accessways will remain open during an emergency event. This can be achieved by either having magnetic hold open doors or doorless open entryways.

1. Platform is enclosed with platform screen doors. It is assumed that smoke and airflow from trackways will only travel to the platform through open platform screen doors that will align with open train doors.



2. Elevators and emergency egress stairways where doors typically remain closed are assumed to have no contributions to airflow and are therefore modeled as a solid obstruction
3. The objective for emergency ventilation is to provide a pressure differential between the incident location and the non-incident location. A higher pressure at a non-incident location is desirable so that the direction of airflow is from the non-incident location towards the incident location. Indicating a resistance of smoke ingress to the non-incident location.
4. Initial indications for successful emergency ventilation operation includes the ability to maintain critical velocity. This is the air velocity in the incident bore required to prevent the back layering of smoke. Critical velocity applies only to push pull ventilation scenarios where on one side of the fire is in exhaust and one side is in supply providing longitudinal airflow. An initial pass/fail criterion for a push-pull ventilation scenario is a velocity greater than 459 FPM within a tunnel segment, and 481 FPM for a station track with platform screen doors. See 4.3 Appendix F for critical velocity calculations.

### 3.2.1 Design Fire Scenario

There are 3 different fire scenarios achieved in this case a train fire, track fire and a platform fire. The train fire is based on the DART D2 rolling stock (SLRV). The peak fire heat release rate is assumed to be 14.9 MW. The track fire is assumed to have a peak heat release rate of 3.5 MW. The platform fire is assumed to have a peak heat release rate of 1.5 MW.

All fire growth rates are based on a  $t^2$  growth rate defined by:

$$\dot{Q} = \alpha t^2$$

Where

$\dot{Q}$  is the heat release rate in W

$\alpha$  is the growth rate coefficient 11.722 w/s<sup>2</sup> for a train fire. This represents a medium growth rate


$\alpha$  is the growth rate coefficient 187.55 w/s<sup>2</sup> for a track and station fire. This represents an ultra fast growth rate.

t is time in seconds

Fire growth rate curve is shown in Figure 9.

Additional user defined characteristics were implemented as well:

- Heat of Combustion of 39.4 MJ/kg.
- Soot Yield of 0.165 kg (soot) /kg (fuel).
- Water Yield of 0.695 kg (water)/kg (fuel).
- CO Yield of 0.14 kg (CO)/kg (fuel).
- Mass specific extinction coefficient for smoke produced by pyrolysis  $K_m=4703 \text{ m}^2/\text{kg}$



**Figure 9: Fire Growth Rate**

### Carbon Monoxide Model

One product of combustion includes Carbon Monoxide (CO) Species development for Carbon monoxide which is specified by 0.14 kg/kg at the fire source. Although carbon monoxide exposure is an important characteristic in determining tenability of an egress path this study used visibility obscuration due to smoke as the determining factor for tenability.

### Smoke Model

Species development for smoke in the CFD simulation is guided by a soot yield factor of 0.165 kg/kg. A custom field function in fluent is used to visualize areas within the station that would be impacted by smoke. The numerical scale used to visualize smoke obscuration in CFD Fluent model is from 0 to 10 m where 0 represents an area where smoke completely obscures the visibility of passengers and 10 represents an unobstructed sight range of 10 meters.

### 3.2.2 SES Inputs

SES software is an engineering tool programmed to evaluate complex flow relationships throughout an underground rail system envelope by ventilation system operations in multiple locations. Used as a standard method in the transportation industry, SES provides accurate prediction of airflows in managing underground hazard conditions. SES software incorporates evaluation of radiation and convection heat transfer, climatic influences on airflow, pressure and airflow relationships, and influences of train piston effect in its calculations.

Inputs and assumptions for the SES simulations include:

1. Outdoor air temperature is 70.6 degrees F and 61.6 degrees F wb<sup>1</sup>
2. Tunnel air temperature is 81.2 degrees F and 63.3 degrees F wb
3. Rolling stock is DART Kinkisharyo
4. Friction loss was calculated based on input of wall roughness of 0.01 ft on concrete surface, and the other areas with fixtures such as lightings, wirings, etc are assumed 0.127 ft.

To develop the appropriate pressure losses associated with the underground station. A non-dimensional factor k applied at various locations where cross section area changes, turns, and other locations there would be a resistance to airflow.

**Table 3: SES K Factors**

Geometry	K factor	
	Forward Positive	Forward Negative
Cross sectional area changes from Tunnel to Station	0.06	0.04
Open Track Damper	2.205	2.205
Open Over Track Exhaust	2	2
Open Over Platform Exhaust	1	1
Fan Plant	0.259	0.259
Open Platform screen doors	4	4


### 3.2.3 CFD Input

#### Geometry Simplifications

CFD model of current Commerce Station configuration is shown in Figure 10: CFD Model. Modifications were made to the station configuration to simplify the CFD analysis, these include simplifying the ventilation path to surface, excluding limited airflow paths from the model, which includes emergency egress stairs, and elevators.

<sup>1</sup> Reference ASHRAE Climatic Design Conditions 2017





**Figure 10: CFD Model**

CFD simulation assumes the walls as no slip boundary, standard wall roughness with a roughness constant of 0.5 is assumed. The walls participate in the thermal radiation calculation and conjugate heat transfer boundary condition are applied.

Ventilation related boundary conditions as shown in Figure 10 are listed in Table 4.

**Table 4: Ventilation flow parameters for fire scenario (a), (b), and (c)**

CFD Simulation No.	R9_3r2	R9_4	R9_5
Fire Scenario	(a)	(b)	(c)
CSW Exhaust	-210.0	-78.8	-79.5
CSE Exhaust	-205.2	-73.1	-79.5
NW Portal	6.5	10.2	11.7
NE Portal	Open	Open	Open
SW Portal	153.3	67.2	32.8




SE Portal	150.3	-39	-31.4
West Headhouse Entrance	Open	Open	Open
East Headhouse Entrance	Open	Open	Open
OPE Damper	Open	Closed	Open
OTE Damper	Open	Open	Closed

Notes:


1. Values for flow parameters are based on SES Results.
2. The 'Open' designation refers to a 0 gauge pressure inlet boundary condition. This allows the CFD program to determine what the flow rate is at the location. This is done to prevent over constraining the CFD simulation.
3. The 'Closed' designation refers to a wall boundary condition, which doesn't allow flow through the boundary.
4. Positive values refer to airflow into the station domain, negative values indicate airflow out of the station domain.

The train geometry for the DART D2 project is modeled after the Kinkishayo Super Light Rail Vehicle (SLRV). It is assumed during a fire scenario only doors located on the platform side are open to allow passenger egress. Windows would be broken due the heat of the fire and is there simulated as open as well.



**Figure 11: CFD Train**

Geometry simplifications were made to the CFD model to improve cell quality and count. For example, the semicircular space above the trackway used for duct space of approximately 66 SF has been represented with rectangular duct with a similar hydraulic diameter and a slightly smaller area of 64 SF as shown in Figure 12. This is done because circular geometry is more complicated for meshing. After applying geometry simplifications, overall cell count of the model after meshing is 3.8 million cells. The cell size around the simplified duct ranges from  $(0.25^3)$  ft<sup>3</sup> to roughly 1 ft<sup>3</sup>.



**Figure 12: Geometry Simplification**

Fires within the station will be exhausted through over track dampers. Over Track Dampers are currently sized at 50 SF.

## 4 Results and Discussion

### 4.1 SES Results

A summary of the SES simulations are shown in Table 5, more details are provided in the SES simulation tracker in Appendix B. SES simulations are used to establish the entire airflow network within the underground alignment. SES runs can typically provide an initial indicator of a pass or fail criteria with longitudinal ventilation schemes, detailing whether a simulation has achieved 'critical velocity' for push pull scenarios. For station extraction cases the airflow rates from SES simulations are used as boundary conditions for subsequent CFD simulations to determine if the case passes or fails. The station extraction cases (1-5) are done using a SES model with platform screen doors (PSD) only on Commerce station. The push pull cases (6-11) are done using a SES model with PSDs on all stations. For more detail see Appendix B and C.

**Table 5: SES Simulations**

SES Simulation No. (Case #)	3r2	4	5	6	7	10	11r1	9
Station Fire Scenario	(a)	(b)	(c)	N/a	N/a	N/a	N/a	N/a
SES File Name	D2_case3r2	D2_case4	D2_case5	D2_push pull_01	D2_push pull_02	D2_push pull_03	D2_push pull_04r1	D2_push pull_01r2
Fire Location	625	625	605	106	306	118	318	102
Fire Zone	410	410	420	120	100	300	320	120
Evac. Direction	West/East	West/East	West/East	West	West	East	East	West
Smoke Direction	Extraction	Extraction	Extraction	East	East	West	West	East
MCW	-	-	-	2E	2E	-	-	3E
MCE	-	-	-	-	-	2E	2E	-
CSW	1E	1E	1E	-	-	2S	2S	-
CSE	1E	1E	1E	-	-	-	-	-
CBW	-	-	-	-	-	-	-	-
CBE	-	-	-	-	-	-	-	-
Pass/Fail	N/a	N/a	N/a	Pass	Pass	Pass	Pass	Pass

**Notes:**

1. For further detail see the node network diagrams in Appendix C. As well as results in Appendix B
2. See Appendix D for ventilation schematic with ventilation zones labeled.
3. Critical velocity applies to longitudinal ventilation, and not extraction ventilation.
4. Pass Fail criteria undetermined in extraction ventilation cases using SES of the 2D nature of its analysis CFD simulation is required to determine if simulation passes.
5. There are 2 fan plants in each station, each fan plant consists of three fans, 2E refers to two fans in a fan plant operating in exhaust mode, 2S refers to two fans in a fan plant operating in supply mode.

**4.1.1 Case No. 3r2 (Fire Scenario (a)):**

This case represents Fire Scenario (a). This scenario entails a middle train fire event within the south track. The ventilation system is postured in an extraction configuration where the west and east fan plant (CSW) and (CSE) are both in exhaust. Platform screen doors on the south track are open, and eastbound over track ventilation dampers are open, as well as over platform dampers. The area of the ventilation adit is updated according to the 30% plans.




Figure 13: SES Case No. 3r2 Diagram

#### 4.1.2 Case No. 4 (Fire Scenario (b)):

This case represents Fire Scenario (b). This scenario entails fire event within the south track with no trains present. The ventilation system is postured in an extraction configuration where the west and east fan plant (CSW) and (CSE) are both in exhaust. Platform screen doors on the south track are open, and eastbound over track ventilation dampers are open.




Figure 14: SES Case No. 4 Diagram

#### 4.1.3 Case No. 5 (Fire Scenario (c)):

This case represents Fire Scenario (c). This scenario entails a fire event within the enclosed platform. The ventilation system is postured in an extraction configuration where the west and east fan plant (CSW) and (CSE) are both in exhaust. Dampers within the enclosed platform are open.




Figure 14: SES Case No. 5 Diagram

#### 4.1.4 Case no. 6 (tunnel fire):

This case represents a tunnel fire in Eastbound track between west portal and metro center station. For this case the evacuation direction is towards the portal (west) and the smoke extraction direction is towards metro station (east). Fire zone is 120. Fire location near Metro Center Station. Two fans in the metro station west plant (MCW) are operating in exhaust mode. Critical velocity is achieved. Non incident tunnel track dampers 902 and 907 are closed.





Figure 16: SES Case No. 6 Diagram

#### 4.1.5 Case no. 7(tunnel fire):


Tunnel fire in Westbound track between west portal and metro center station. For this case the evacuation direction is towards the portal (west) and the smoke extraction direction is towards metro center station (east). Fire zone is 100. Two fans in the metro station west plant (MCW) are operating in exhaust mode. Critical velocity is achieved. Non incident tunnel track dampers 901 and 906 are closed.



### Figure 17: SES Case No. 7 Diagram

#### 4.1.6 Case no. 10 (Tunnel fire):

Tunnel fire in Eastbound track between metro station and commerce station. For this case the evacuation direction is towards the commerce station (CS) and the smoke extraction direction is towards metro center station (east). Fire zone is 320. Two fans in the metro station east plant (MCE) are operating in exhaust mode and two fans in commerce station west plant (CSW) in supply mode. Critical velocity is achieved. Non incident tunnel track dampers 907 and 912 are closed.



### Figure 18: SES Case No. 10 Diagram

#### 4.1.7 Case no. 11r1 (Tunnel fire):

Tunnel fire in Westbound track between metro center station and commerce station. For this case the evacuation direction is towards the commerce station (CS) and the smoke extraction direction is towards metro center station (east) Fire zone is 300. Two fans in the metro center station east plant (MCE) is operating in exhaust mode and two fans in commerce station west plant (CSW) in supply mode. Critical velocity is achieved. Non incident tunnel track dampers 906 and 911 are closed.




Figure 19: SES Case No. 11 Diagram

#### 4.1.8 Case no.9 (Tunnel fire):

Tunnel fire in Eastbound track near west portal. For this case the evacuation direction is towards the portal (west) and the smoke extraction direction is towards metro station (east). Fire zone is 120. **Three** fans in the metro station west plant (MCW) are operating in exhaust mode. Critical velocity is achieved. Non incident tunnel track dampers 902 and 907 are closed. Three fans have to be turned on to achieve critical velocity due to the 6% slope of the tunnel near the west portal.




Figure 20: SES Case No. 9 Diagram

#### 4.1.9 Case no.12: Piston effects pressure relief calculations

When a train approaches or departs the station, excessive pressure change should be controlled to avoid rate of pressure change more rapid than 1.7 in. w.g. per second. This analysis considered the updated geometry of the adits and the duct with cross section areas of 220 sf and 85sf, respectively. Cross section area input into the SES simulation is representative of the area designed into the system and accounts for other impacts such as total shaft volume and friction loss conditions. SES modelling results are given in Figure 21, which confirmed that the maximum pressure change is less than the threshold value of 0.06 psi/sec (1.7 in w.g./s)




Figure 21: SES case No. 12




Figure 22: Pressure change with time at segment 130 for SES case.12

## 4.2 CFD Results

Results from CFD simulations are provided in Table 6 . Further details can be found in 4.3Appendix E. Note the train fire simulation starts 4 minutes after fire has begun to grow.



**Table 6: CFD Results**

CFD Config. ID	(Name)	R9_3r2	R9_4	R9_5
SES Case	(Case #)	3r1	4	5
Fire Scenario		(a)	(b)	(c)
Fire Location		South Track Middle Train	South Track No Train	Center Platform
Exhaust Scheme		Extraction	Extraction	Extraction
Smoke Direction		Extraction	Extraction	Extraction
Input Boundary Conditions (KCFM)	Prtl NW	6.5	10.2	11.7
	Prtl NE	Vent	Vent	Vent
	Prtl SW	153.2	67.2	32.5
	Prtl SE	150.3	39	31.4
	West Vent	-210	-78.8	-79.5
	East Vent	-205.2	-73.1	-79.5
Recorded Boundary Conditions (KCFM) <sup>3</sup>	Prtl NW	6.5	10.2	11.7
	Prtl NE	-7.1	-10.6	-11.9
	Prtl SW	153.2	67.2	32.5
	Prtl SE	150.3	39	31.4
	West Vent	-210	-78.8	-79.5
	East Vent	-205.2	-73.1	-73.1
Pass/Fail <sup>1</sup>		Pass	Fail	Pass

1. Simulation pass/fail is determined by the system's ability to keep smoke from propagating towards egress walkway paths.
2. A positive value indicates supply from a boundary condition (airflow "into" domain). A negative value indicates exhaust from the domain.
3. Simulation results updated upon completion

#### 4.2.1 Case No.3r2

The CFD configuration represents fire scenario 1 where a center train on the south track is on fire. The ventilation method used for this scenario is the same as SES Case no.3r1 with an extraction ventilation approach. In this case both the west fan plant (CSW) and the east fan plant (CSE) are in exhaust with both the OTE and OPE terminals open. Simulation time is 4 minutes (8 minutes after fire has started). Results indicate that smoke is maintained with the center of the platform where the OPE terminals are. Note this assumes there is a path for makeup air to enter the platform from the east headhouse.




Figure 23: Case 3 - Smoke visibility at 4 mins after evacuation (8 mins since fire starts)

#### 4.2.2 Case No.4

The CFD configuration represents fire scenario 2 where there is a miscellaneous track fire. The ventilation method used for this scenario is the same as SES Case no.4 with an extraction ventilation approach. In this case both the west fan plant (CSW) and the east fan plant (CSE) are in exhaust with the OTE open. Simulation is stopped after 7 minutes; results indicate that smoke is not maintained within the track area and, is heading towards the east headhouse.




Figure 24: Case 4 - Smoke visibility at 4 mins after evacuation (8 mins since fire starts)

### 4.2.3 Case No.5

The CFD configuration represents fire scenario 3 where a fire occurs on the platform. The ventilation method used for this scenario is the same as SES Case no.5 with an extraction ventilation approach. In this case both the west fan plant (CSW) and the east fan plant (CSE) are in exhaust and OPE terminals open. Simulation time is stopped after 8 minutes when it is assumed all passengers have evacuated the platform. Results indicate that smoke is maintained with the center of the platform where the OPE terminals are. Note this assumes there is a path for makeup air to enter the platform from the east headhouse.




Figure 25: Case 5 - Smoke visibility at 4 mins after evacuation (8 mins since fire starts)

## 4.3 Discussion and Future Considerations

The current ventilation concept seems to be effective at exhausting smoke within the station. With the exception of case 4 which can be mitigated if we maintain closed platform screen doors isolating the track from the platform. Ventilation Simulations are preliminary and should be refined in future efforts. Current ventilation plenum sizes may not be adequate enough for flow rates established during emergency Ventilation operations. See Appendix F for space proofing concept. Although the CFD model follows the current sizes for ductwork along the Commerce Street Station; the established flow rates from SES results were based on k factor calculations using larger ducts as shown in appendix A. Additionally section 4.2.1 shows that makeup air is needed at the east headhouse. Currently the only public access at this location is Elevator only, so there isn't a reliable way to introduce makeup airflow. Future consideration for a shaft to grade would help mitigate this as shown in Appendix D.



## Appendix A. Fan Pressure Calculation

DRAFT



Made By: jn Date: 2/10/2020 Job No.: 61144  
Checked by: tv Date: 2/21/2020 Sheet No.:  
Bkchk by: Date: File Name: \\seaw00\jobs\2161144\Redbook\08\_TechProd\20%\_Cncpt\_Dsgn\_Rpt\{Dart D2 Duct Minor Losses.xlsx}HV-1 with Fan

1

PROJECT NAME: DART D2

CALCULATION: Comparison of Duct Section with Abrupt Contraction @ Silencer Outlet To Flex Connection - Study of Airflow At Outlet of Baffle To Flex Connection

Air density at 70deg F and 14.7 psia: 0.081 lbm/ft<sup>3</sup>  
Air temperature 32 deg F.

HIDE THE ORANGE ROWS FOR PRINTING

1. ENTER RECTANGULAR DUCT SIZE OR ROUND DUCT SIZE, NOT BOTH. FORMULAS WILL IGNORE RECTANGULAR DUCT SIZE IF ROUND DUCT SIZE IS ENTERED INTO CELL.
2. VALUES IN COLUMN "Duct Pressure Drop/100 ft (in. w. water)" WILL BE RED TEXT WITH RED SHADE BACKGROUND IF PRESSURE DROP EXCEEDS 0.25 IN WATER PER 100 FT


Duct Section	Fitting Name	ASHRAE Fitting(s) No. (Ref 1, 2)	Duct Material	Duct Roughness, ft.	Terminal/Branch Airflow (cfm)	Airflow (cfm)	Rectangular Duct Size			Duct Size (Dia., in.)	Duct Area (ft²)	Room NC/ Max Velocity (fpm)	Velocity (fpm)	Velocity Pressure (in. water)	Duct Length (ft)	Summary of Fitting Loss Coefficients	Reynolds Number Re (Ref 4)	Friction Factor f (Ref 3)	Duct Pressure Drop/100 ft (in. water)	Fitting Pressure Drop (in. water)	Equipment Pressure Drop (in. water)	Total Pressure Drop (in. water)	Notes	
							Duct Size (W, in.)	Duct Size (L, in.)	Duct Size (Dh, in.)															
1	Damper	Fig 2.28	Galv. Stl.	0.0005	500000	500000	144	156	149.76	156.00	35/2000	3205	0.6918			0.44	4.69E+06	0.0000	0.0000	0.3044		0.3044	1, 2	
2	Entry	Fig 2.28	Galv. Stl.	0.0005	500000	500000	144	156	149.76	156.00	35/2000	3205	0.6918			0.5	4.69E+06	0.0109	0.0602	0.3459		0.3459	1, 2	
3	90deg turn	Fig 2.28	Galv. Stl.	0.0005	500000	500000	144	156	149.76	156.00	35/2000	3205	0.6918			1.2	4.69E+06	0.0109	0.0602	0.8302		0.8302	1, 2	
4	Length	Fig 2.28	Galv. Stl.	0.0005	500000	500000	144	156	149.76	156.00	35/2000	3205	0.6918	170.00			4.69E+06	0.0109	0.0602	0.0000		0.1024	1, 2	
5	Abrupt open	Fig 2.28	Galv. Stl.	0.0005	500000	500000	276	138	184	264.50	35/2000	1890	0.2406			0.3	3.40E+06	0.0109	0.0170	0.0722		0.0722	1, 2	
6	90deg turn	Fig 2.28	Galv. Stl.	0.0005	500000	500000	408	120	185.45455	340.00	35/2000	1471	0.1456			1.2	2.67E+06	0.0111	0.0104	0.1748		0.1748	1, 2	
7	Length	Fig 2.28	Galv. Stl.	0.0005	500000	500000	408	120	185.45455	340.00	35/2000	1471	0.1456	35.00			2.67E+06	0.0111	0.0104	0.0000		0.0037	1, 2	
8	Contraction	Fig 2.28	Galv. Stl.	0.0005	500000	500000	318	120	174.24658	265.00	35/2000	1887	0.2397			0.05	3.22E+06	0.0110	0.0181	0.0120		0.0120	1, 2	
9	Length	Fig 2.28	Galv. Stl.	0.0005	500000	500000	228	120	157.24138	190.00	35/2000	2632	0.4664	32.00			4.05E+06	0.0109	0.0388	0.0000		0.0124	1, 2	
10	Contraction	Fig 2.28	Galv. Stl.	0.0005	500000	250000	174	120	142.04082	145.00	35/2000	1724	0.2002			0.05	2.40E+06	0.0114	0.0194	0.0100		0.0100	1, 2	
10.1	Length	Fig 2.28	Galv. Stl.	0.0005	500000	250000			#DIV/0!	120	78.54	35/2000	3183	0.6823	10.00			3.74E+06	0.0113	0.0771	0.0000		0.0077	1, 2
10.2	Silencer	Fig 2.28	Galv. Stl.	0.0005	500000	250000			#DIV/0!	120	78.54	35/2000	3183	0.6823			0.55	3.74E+06	0.0000	0.0000	0.3753		0.3753	1, 2
10.3	Contraction	Fig 2.28	Galv. Stl.	0.0005	500000	250000			#DIV/0!	104.00	58.99	35/2000	4238	1.2094			0.05	4.31E+06	0.0114	0.1595	0.0605		0.0605	1, 2
10.4	Motor	Fig 2.28	Galv. Stl.	0.0005	500000	250000			#DIV/0!	88	42.24	35/2000	5919	2.3593				5.09E+06	0.0116	0.3739	0.0000		0.0000	1, 2
10.5	Diffuser	Fig 2.28	Galv. Stl.	0.0005	500000	250000			#DIV/0!	104.00	58.99	35/2000	4238	1.2094			0.12	4.31E+06	0.0114	0.1595	0.1451		0.1451	1, 2
10.6	Silencer	Fig 2.28	Galv. Stl.	0.0005	500000	250000			#DIV/0!	120.00	78.54	35/2000	3183	0.6823			0.55	3.74E+06	0.0000	0.0000	0.3753		0.3753	1, 2
10.7	Length	Fig 2.28	Galv. Stl.	0.0005	500000	250000			#DIV/0!	120	78.54	35/2000	3183	0.6823	10.00			3.74E+06	0.0113	0.0771	0.0000		0.0077	1, 2
11	Diffuser	Fig 2.28	Galv. Stl.	0.0005	500000	500000	201	258	225.96078	360.13	35/2000	1388	0.1298			0.5	3.07E+06	0.0108	0.0074	0.0649		0.0649	1, 2	
12	90deg turn	Fig 2.28	Galv. Stl.	0.0005	500000	500000	228	396	289.38462	627.00	35/2000	797	0.0428			1.2	2.26E+06	0.0109	0.0019	0.0514		0.0514	1, 2	
13	Length	Fig 2.28	Galv. Stl.	0.0005	500000	500000	228	396	289.38462	627.00	35/2000	797	0.0428	90.00			2.26E+06	0.0109	0.0019	0.0000		0.0017	1, 2	
14	Exit w/ elbow	Fig 2.28	Galv. Stl.	0.0005	500000	500000	228	396	289.38462	627.00	35/2000	797	0.0428			1.8	2.26E+06	0.0109	0.0019	0.0771		0.0771	1, 2	
15	Damper	Fig 2.28	Galv. Stl.	0.0005	500000	500000	228	396	289.38462	627.00	35/2000	797	0.0428			0.44	2.26E+06	0.0109	0.0019	0.0188		0.0188	1, 2	
Total																					3.0534			

#### References:

1. ASHRAE Duct Fitting Database, Version 2.2.5
2. 1989 Fundamentals, Chapter 32, Fitting Loss Coefficients
3. ASHRAE 1997 Fundamentals, Equation 32.20
4. ASHRAE 1997 Fundamentals, Equation 32.21
4. ASHRAE 1981 Fundamentals, Chapter 33, Duct Design



#### Notes:

1. Fittings are located at the beginning of a duct section
2. Equipment is located at the end of a duct section
3. Equipment loss is for register
4. Equipment loss is for combination fire/smoke damper



Total Vol 102500.8	Section Pressure Drop				Resulting Drop	
	Area (ft <sup>2</sup> )	V (fpm)	K-factor to achieve drop			
	1.8298	156	3205.1282	2.645314737	1.830013698	
	1.2236	400	1250	11.63033291	1.223765906	

F.S. 20% 4.58



- KEYED BUBBLE IDENTIFICATION:
- 1 TRAINWAY VENTILATION TERMINAL
  - 2 OVER TRACK EXHAUST TERMINAL
  - 3 ENCLOSED STAIR SHAFT
  - 4 ELEVATOR LOBBY
  - 5 ELEVATOR SHAFT
  - 6 VENTILATION PLANT
  - 7 VENTILATION SHAFT

CM-STREET LEVEL OVERALL PLAN  
SCALE: 1" = 40'-0"

NOT AN APPROVED DRAWING  
PRELIMINARY 20% DESIGN

REV	△	AMEND	CR	DATE	DESCRIPTION	BY	ENG	CHK	APP

IN-PROGRESS  
THIS DOCUMENT IS RELEASED  
FOR THE PURPOSE OF REVIEW UNDER THE  
AUTHORITY OF:  
  
IT IS NOT TO BE USED FOR CONSTRUCTION,  
BIDDING, OR PERMIT PURPOSES.

**DART PROJECT**  
  
© DART, all rights reserved, 1987-2019

SCALE	1" = 40'-0"
DRAWN	Author
DESIGNED	Designer
CHECKED	Checker
IN CHARGE	Checker
DATE	01/15/2020



CONTRACT SHEET No. \_\_\_\_\_ OF SHT TOTAL \_\_\_\_\_

**LIGHT RAIL TRANSIT SYSTEM  
LINE SECTION CBD-2**

**COMMERCE STATION  
OVERALL STREET FLOOR PLAN**

CONTRACT	DWG No.	REV
10024656	AC1-3010	





1  
AC2-3210

NOT AN APPROVED  
PRELIMINARY 20% DESIGN

CONTRACT
----------

O SHT

## LIGHT RAIL TRANSIT SYSTEM LINE SECTION CBD-2

COMMERCE STATION  
OVERALL UPPER LEVEL FLOOR PLAN

[illegible]

IN-PROGRESS  
THIS DOCUMENT IS  
RELEASED

FOR THE PURPOSE OF

IT IS NOT TO BE USED FOR  
CONSTRUCTION,



## DART PROJECT



© DART, all rights reserved, 1987-2019

SCALE	1" = 40'-0"
DRAWN	Author
DESIGNED	Designer
CHECKED	Checker
IN CHARGE	Checker
DATE	01/16/2020



CONTRACT  
10024656

DWG No.	AC2-3210
---------	----------

REV

Tunnel Ventilation

Station HVAC



CBD2-EB

SCALE: 1" = 40'-0"


AC2-3310

IN-PROGRESS  
THIS DOCUMENT IS RELEASED  
FOR THE PURPOSE OF REVIEW UNDER THE  
AUTHORITY OF:  
IT IS NOT TO BE USED FOR CONSTRUCTION  
BIDDING, OR PERMIT PURPOSES.



© DART, all rights reserved, 1987-2019

SCALE	1" = 40'-0"
DRAWN	Author
DESIGNED	Designer
CHECKED	Checker
IN CHARGE	Checker
DATE	01/16/2020




COMMERCE STATION  
OVERALL MIDDLE LEVEL FLOOR PLAN

2020	CONTRACT 10024656
------	----------------------

DWG No.	AC2-3310
---------	----------

EV





## KEY PLAN

- KEYED BUBBLE IDENTIFICATION:**
- 1 TRAINWAY VENTILATION TERMINAL
  - 2 OVER TRACK EXHAUST TERMINAL
  - 3 ENCLOSED STAIR SHAFT
  - 4 ELEVATOR LOBBY
  - 5 ELEVATOR SHAFT
  - 6 VENTILATION PLANT
  - 7 VENTILATION SHAFT

CBD2-WB

CBD2-EB

CM-LOWER MEZZANINE LEVEL OVERALL PLAN

SCALE: 1" = 40'-0"

1  
C2-3410

IN-PROGRESS

THIS DOCUMENT IS RELEASED  
FOR THE PURPOSE OF REVIEW UNDER THE  
AUTHORITY OF:

IT IS NOT TO BE USED FOR CONSTRUCTION,  
BIDDING, OR PERMIT PURPOSES.



## DART PROJECT



© DART, all rights reserved, 1987-2019

SCALE	1" = 40'-0"
DRAWN	Author
DESIGNED	Designer
CHECKED	Checker
IN CHARGE	Checker
DATE	01/16/2020



CONTRACT SHEET No.	OF SHT TOTAL
--------------------	--------------

## LIGHT RAIL TRANSIT SYSTEM LINE SECTION CBD-2



COMMERCE STATION  
OVERALL LOWER LEVEL FLOOR PLAN

CONTRACT	10024656
----------	----------


DWG No.	AC2-3410
---------	----------

5

[illegible]



CM-PLATFORM LEVEL OVERALL PLAN  
SCALE: 1" = 40'-0"



NOT AN APPROVED DRAWING  
PRELIMINARY 20% DESIGN

CONTRACT SHEET No.	OF SHT TOTAL
--------------------	--------------

LIGHT RAIL TRANSIT SYSTEM  
LINE SECTION CBD-2

COMMERCE STATION  
OVERALL PLATFORM LEVEL FLOOR PLAN

[illegible]

IN-PROGRESS

THIS DOCUMENT IS RELEASED

FOR THE PURPOSE OF REVIEW UNDER THE

AUTHORITY OF:

IT IS NOT TO BE USED FOR CONSTRUCTION

BIDDING, OR PERMIT PURPOSES.



## DART PROJECT



© DART, all rights reserved, 1987-2019

SCALE	1" = 40'-0"
DRAWN	Author
DESIGNED	Designer
CHECKED	Checker
IN CHARGE	Checker
DATE	01/16/2020





CONTRACT	10024656
----------	----------

DWG No.	AC2-3510
---------	----------

EV





CM-PLATFORM LEVEL SECTOR PLANS – D1

SCALE: 1/8" = 1'-0"

1  
AC2-3516

IN-PROGRESS  
THIS DOCUMENT IS  
RELEASED

FOR THE PURPOSE OF

IT IS NOT TO BE USED FOR  
CONSTRUCTION,



## DART PROJECT



© DART, all rights reserved, 1987-2019

SCALE	1/8" = 1'-0"
DRAWN	Author
DESIGNED	Designer
CHECKED	Checker
IN CHARGE	Checker
DATE	01/16/2020

CONTRACT

O SHT

## LIGHT RAIL TRANSIT SYSTEM LINE SECTION CBD-2


COMMERCE STATION  
PLATFORM LEVEL SECTOR PLAN D1

CONTRACT  
10024656

DWG No.	AC2-3516
---------	----------

REV

REV	AMEND	CR	DATE	DESCRIPTION	BY	ENG	CHK	APP
-----	-------	----	------	-------------	----	-----	-----	-----



3-A

Tunnel Ventilation

Station HVAC

1  
AC2-3517


O SHT

REV

HDR



REV	AMEND	CR	DATE	DESCRIPTION	BY	ENG	CHK	APP
-----	-------	----	------	-------------	----	-----	-----	-----



CM-PLATFORM LEVEL SECTOR PLANS – D3

SCALE: 1/8" = 1'-0"

1  
AC2-3518

NOT AN APPROVED  
PRELIMINARY 20% DESIGN

CONTRACT

O SHT

## LIGHT RAIL TRANSIT SYSTEM LINE SECTION CBD-2

COMMERCE STATION  
PLATFORM LEVEL SECTOR PLAN D3

## DART PROJECT

SCALE	$1/8" = 1'-0"$
-------	----------------

DRAWN

DESIGNED	Author
----------	--------

DESIGNED	Designer
CHECKED	

IN CHARGE	Checker
-----------	---------

IN CHARGE	Checker
DATE	

**DART**

© DART, all rights reserved, 1987-2019



CONTRACT  
10024656

DWG No.	AC2-3518
---------	----------

REV

REV	AMEND	CR	DATE	DESCRIPTION
-----	-------	----	------	-------------

BY	ENG	CHK	APP
----	-----	-----	-----

IN-PROGRESS  
THIS DOCUMENT IS  
RELEASED

FOR THE PURPOSE OF



IT IS NOT TO BE USED FOR  
CONSTRUCTION,

H2R



**DART**





- KEYED BUBBLE IDENTIFICATION:**
1. TRAINWAY VENTILATION TERMINAL
  2. OVER TRACK EXHAUST TERMINAL
  3. ENCLOSED STAIR SHAFT
  4. ELEVATOR LOBBY
  5. ELEVATOR SHAFT
  6. VENTILATION PLANT
  7. VENTILATION SHAFT

Tunnel Ventilation

Station HVAC

CM-PLATFORM LEVEL SECTOR PLANS - D4  
SCALE: 1/8" = 1'-0"

1  
AC2-3519

IN-PROGRESS  
THIS DOCUMENT IS  
RELEASED  
FOR THE PURPOSE OF  
IT IS NOT TO BE USED FOR  
CONSTRUCTION,



## DART PROJECT



© DART, all rights reserved, 1987-2019

SCALE	1/8" = 1'-0"
DRAWN	Author
DESIGNED	Designer
CHECKED	Checker
IN CHARGE	Checker
DATE	01/16/2020





NOT AN APPROVED  
PRELIMINARY 20% DESIGN

CONTRACT	O SHT
----------	-------

## LIGHT RAIL TRANSIT SYSTEM LINE SECTION CBD-2

COMMERCE STATION  
PLATFORM LEVEL SECTOR PLAN D4

CONTRACT 10024656	DWG No. AC2-3519	REV
----------------------	---------------------	-----



- KEYED BUBBLE IDENTIFICATION:
- 1 TRAINWAY VENTILATION TERMINAL
  - 2 OVER TRACK EXHAUST TERMINAL
  - 3 ENCLOSED STAIR SHAFT
  - 4 ELEVATOR LOBBY
  - 5 ELEVATOR SHAFT
  - 6 VENTILATION PLANT
  - 7 VENTILATION SHAFT

CM-PLATFORM LEVEL SECTOR PLANS - D5  
SCALE: 1/8" = 1'-0"

REV	AMEND	CR	DATE	DESCRIPTION	BY	ENG	CHK	APP

IN-PROGRESS  
THIS DOCUMENT IS  
RELEASED  
FOR THE PURPOSE OF

IT IS NOT TO BE USED FOR  
CONSTRUCTION,



DART PROJECT

C DART, all rights reserved, 1987-2019

SCALE	1/8" = 1'-0"
DRAWN	Author
DESIGNED	Designer
CHECKED	Checker
IN CHARGE	Checker
DATE	01/15/2020

NOT AN APPROVED  
PRELIMINARY 20% DESIGN



CONTRACT O SHT

LIGHT RAIL TRANSIT SYSTEM  
LINE SECTION CBD-2

COMMERCE STATION  
PLATFORM LEVEL SECTOR PLAN D5

CONTRACT	DWG No.	REV
10024656	AC2-3520	



[illegible]

HDR



© DART, all rights reserved, 1987-2019

SCALE	1/8" = 1'-0"
DRAWN	Author
DESIGNED	Designer
CHECKED	Checker
IN CHARGE	Checker
DATE	01/16/2020




COMMERCE STATION  
PLATFORM LEVEL SECTOR PLAN E3

CONTRACT  
10024656

DWG No.	AC2-3521
---------	----------

REV

CM-Section 4 - 3012

SCALE:  $1/8" = 1'-0"$

1

AC5-3011

NOT AN APPROVED  
PRELIMINARY 20% DESIGN

CONTRACT

O SHT

# LIGHT RAIL TRANSIT SYSTEM LINE SECTION CBD-2

## COMMERCE STATION STATION CROSS SECTIONS

REV	AMEND	CR	DATE	DESCRIPTION
-----	-------	----	------	-------------

BY	ENG	CHK	APP
----	-----	-----	-----

IN-PROGRESS  
THIS DOCUMENT IS  
RELEASED

FOR THE PURPOSE OF

IT IS NOT TO BE USED FOR  
CONSTRUCTION,



## DART PROJECT



© DART, all rights reserved, 1987-2019

SCALE	1/8" = 1'-0"
DRAWN	Author
DESIGNED	Designer
CHECKED	Checker
IN CHARGE	Checker
DATE	01/16/2020



CONTRACT  
10024656

DWG No.	AC5-3011
---------	----------

REV



3-3

3-4

(3-5)

3-6

3-7

(3-8)

3-9

$$\begin{array}{cc} \text{3-10} & \text{3-10.5} \\ \text{10} & \text{10.5} \end{array}$$

(3-11) (3-12)

Commerce - Roof  
EL 455' - 3"

Commerce - Ceiling Level  
EL 450' - 3"

Commerce - Pegasus Plaza  
EL 430' - 3"

Commerce - Upper Mezzanine  
EL 406' - 3"

Commerce - Middle Mezzanine  
EL 396' - 3"

Commerce - Lower Mezzanine  
EL 370' - 0"

Commerce - Platform West (69+91.53)  
EL 354' - 2 1/2"

NOT AN APPROVED  
PRELIMINARY 20% DESIGN

CONTRACT

O SHT

# LIGHT RAIL TRANSIT SYSTEM LINE SECTION CBD-2

### COMMERCE STATION STATION CROSS SECTIONS

IN-PROGRESS  
THIS DOCUMENT IS  
RELEASED

FOR THE PURPOSE OF

IT IS NOT TO BE USED FOR  
CONSTRUCTION,



## DART PROJECT



© DART, all rights reserved, 1987-2019

SCALE	1/8" = 1'-0"
DRAWN	Author
DESIGNED	Designer
CHECKED	Checker
IN CHARGE	Checker
DATE	01/16/2020



CONTRACT  
10024656

DWG No.	AC5-3012
---------	----------

REV

REV	AMEND	CR	DATE	DESCRIPTION
-----	-------	----	------	-------------

BY	ENG	CHK	APP
----	-----	-----	-----





1  
AC5-3013

CONTRACT	O SHT
----------	-------

## COMMERCE STATION STATION CROSS SECTIONS



© DART, all rights reserved, 1987-2019

SCALE	$3/32" = 1' = 0$
DRAWN	Author
DESIGNED	Designer
CHECKED	Checker
IN CHARGE	Checker
DATE	01/16/2020



CONTRACT  
10024656

DWG No.	AC5-3013
---------	----------

REV

FOR THE PURPOSE OF

IT IS NOT TO BE USED FOR  
CONSTRUCTION,

[illegible]



Commerce - Platform West (69+91.53)  
EL 354' - 2 1/2"

CIRCULATION  
3527

— STORM DRAIN BEYOND

Any duct work would need to penetrate the upper metal stud wall of the station and pass within the plenum of the station platform to the other side.

The line highlighted could be a route to use for HVAC under the platform floor.

Commerce Longitudinal Section - AC2-3012

SCALE: 1/16" = 1'-0"

1  
C5-3014

Commerce - Platform West (69+91.53)  
EL 354' - 2 1/2"

(3-15)

The space hatched can and will be used for Ventilation, HVAC elements, and other necessary elements to support the station.

Any duct work would need to penetrate the upper metal stud wall of the station and pass within the plenum of the station platform to the other side.

3-16

$$(3-3-17.5)$$

(3-20)-21

— CUI VERT BEYOND

Commerce - Lower Mezz-East  
TEL 372' - 0"

### Commerce Longitudinal Section – CONT.

SCALE: 1/16" = 1'-0"

2  
C5-3014

The line highlighted could be a route to use for HVAC under the platform floor.

IN-PROGRESS  
THIS DOCUMENT IS  
RELEASED

FOR THE PURPOSE OF

IT IS NOT TO BE USED FOR  
CONSTRUCTION,



## DART PROJECT



© DART, all rights reserved, 1987-2019

SCALE	$1/16" = 1' - 0"$
DRAWN	Author
DESIGNED	Designer
CHECKED	Checker
IN CHARGE	Checker
DATE	01/16/2021

NOT AN APPROVED  
PRELIMINARY 20% DESIGN

CONTRACT

O SHT

**LIGHT RAIL TRANSIT SYSTEM  
LINE SECTION CBD-2**

COMMERCE STATION  
STATION SECTIONS

REV	AMEND	CR	DATE	DESCRIPTION
-----	-------	----	------	-------------

BY	ENG	CHK	APP
----	-----	-----	-----



2020	CONTRACT 10024656
------	----------------------

DWG No.

AC5-3014

REV



(3-DD) (3-EE)

Commerce - Platform East (73+76.53)  
EL 355' - 2 3/4"

BACKGROUND MARKUP  
Cavern Cross Section at East End of Station  
Away from Fan Plant Adits

NOT AN APPROVED  
PRELIMINARY 20% DESIGN

## CONTRACT

O SHT

## LIGHT RAIL TRANSIT SYSTEM LINE SECTION CBD-2

COMMERCE STATION  
STATION SECTIONS

CONTRACT  
10024656


DWG No.

AC5-3018

REV

[illegible]





NOT AN APPROVED  
PRELIMINARY 20% DESIGN

CONTRACT O SHT

LIGHT RAIL TRANSIT SYSTEM  
LINE SECTION CBD-2


COMMERCE STATION  
STATION SECTIONS

CONTRACT 10024656 DWG No. AC5-3018 REV

IN-PROGRESS  
THIS DOCUMENT IS  
RELEASED  
FOR THE PURPOSE OF  
  
IT IS NOT TO BE USED FOR  
CONSTRUCTION,



DART PROJECT



© DART, all rights reserved, 1987-2019

SCALE	1/8" = 1'-0"
DRAWN	Author
DESIGNED	Designer
CHECKED	Checker
IN CHARGE	Checker
DATE	01/16/2020



$$\begin{array}{c} \text{3-CC} \\ \text{3-CC} \end{array}$$

Commerce - Center Street Level  
EL 432' - 3"

Commerce - Platform East (73+76.53)  
EL 355' - 2 3/4"

CBD2-EB

SERVICE  
CORRIDOR  
3231

ELEVATOR  
3112

PRE-FARE  
3110

FARE PAID  
LOBBY  
3111

EGRESS  
CORRIDOR  
3542

FIRE COMMAND  
TRIAGE  
3544

The plenum of the station could be used at this area to provide connection to either side

1

SCALE:  $1/8" = 1'-0"$

AC5-3019

IT IS NOT TO BE USED FOR  
CONSTRUCTION,



© DART, all rights reserved, 1987-2019

SCALE	1/8" = 1'-0"
DRAWN	Author
DESIGNED	Designer
CHECKED	Checker
IN CHARGE	Checker
DATE	01/16/2020



CONTRACT

O SHT

# LIGHT RAIL TRANSIT SYSTEM LINE SECTION CBD-2

COMMERCE STATION  
STATION SECTIONS

CONTRACT  
10024656

DWG No.	AC5-3019
---------	----------

REV



## Appendix B. SES Simulation Results

DRAFT

## Dart D2 SES Run Log

Link to SES files =

## SES files


Link to SES results diagram =

## SES post


[illegible]




# CASE 3r1




## CASE 3r2



## CASE 4



CASE 5



41+50

5.43%

47+60

1.24%

66+25

CSW

↑

79.5

0.3

78.3

0.3

78.3

0.3

78.6

0.3

11.7

0.34%

76+60

4.74%

91+40

1.25%

99+95

6.00%

101+65

COMMERCE

↑

79.5

0.3

78.3

0.3

78.6

0.3

11.2

0.34%

76+60

4.74%

91+40

1.25%

99+95

6.00%

101+65

CBD EAST

↑

121.5

0.3

78.3

0.3

78.6

0.3

10.7

0.34%

76+60

4.74%

91+40

1.25%

99+95

6.00%

101+65

EB TRACK

↑

85.1

32.8

32.5

31.4

31.1

60.8

22.3

59.8

6.00%

101+65

WB TRACK

↑

85.1

32.8

32.5

31.4

31.1

60.8

22.3

59.8

6.00%

101+65

LEGEND

Train

XX.X

AIRFLOW (kcfm)

FAN OPERATING

FAN NOT OPERATING

CLOSED DAMPER

SES FILE :

O:\61144\Redbook\08\_TechProd\SES files\D2\_case5.SES

PROJECT :

DART D2


SCALE :

NTS

DATE :



CASE 6



CSW

↓

-121.7

→

-0.1

←

-156.4

←

-73.4

←

-73.1

←

-36.0

←

-96.7

←

-56.4

↑

103.9

CBW

↓

-5.0

CSE

↓

-121.7

CSW

COMMERCE

CBD EAST

EAST PORTAL

→ 30.4

→ 69.1

→ 37.1

→ 42.8

→ 18.1

→ 32.3

→ 50.4

→ -82.8

→ -38.7

→ -3.7

→ -3.7

→ -3.2

→ 3.0

0.34%

76+60

4.74%

91+40

1.25%

99+95

6.00%

101+65

LEGEND

Train

AIRFLOW (kcfm)

FAN OPERATING

FAN NOT OPERATING

CLOSED DAMPER

SES FILE :

PROJECT :

SCALE :


DATE :

O:\61144\Redbook\08\_TechProd\SES files\D2\_push pull\_01.SES


DART D2

NTS


# CASE 7



## CASE 9




# CASE 10






# CASE 11



# CASE 11r1










## Appendix C. Node Network Diagram

DRAFT

FOR SES CASE 1-5






SIMULATION RESULTS FLOW DIAGRAM  
FIRE SCENARIO AT X

RUN: DATE SHEET

SES NODE NETWORK DIAGRAM  
DART D2, with PSD only in Commerce Station

FOR SES CASE 6-11






SIMULATION RESULTS FLOW DIAGRAM  
FIRE SCENARIO AT X

RUN:      DATE      SHEET

SES NODE NETWORK DIAGRAM  
DART D2, with PSD in all stations

FOR SES CASE 12



SIMULATION RESULTS FLOW DIAGRAM  
FIRE SCENARIO AT X

RUN:      DATE      SHEET

SES NODE NETWORK DIAGRAM  
DART D2-piston relief run, with PSD in all stations.



## Appendix D. Ventilation Schematic

DRAFT



NOT FOR CONSTRUCTION  
NOT AN APPROVED DRAWING  
PRELIMINARY DESIGN



**SCALE: NTS**


[illegible]

THIS IN-PROGRESS DRAWING IS RELEASED  
FOR REVIEW UNDER THE AUTHORITY OF:  
JERRY STEVEN CASEY, P.E. NO. 65588  
ON 10/30/2020  
HNTB CORPORATION  
TBPE FIRM NO. F-420  
IT SHALL BE UPDATED AND  
CONFIRMED UPON COMPLETION OF  
SUBSURFACE INVESTIGATIONS

HNTB Corporation  
The HNTB Companies  
Engineers Architects Planners  
TBPE Firm Registration No.420



SCALE	NO SCALE
DRAWN	S. PARAYIL
DESIGNED	S. PARAYIL
CHECKED	S. CASSADY
IN CHARGE	J. CASEY
DATE	30 OCT 2020



COMMERCE STATION AIRFLOW  
PRESSURIZATION DIAGRAM

CONTRACT	
----------	--

DWG No.

MC 7 - 0002

REV





NOT FOR CONSTRUCTION  
NOT AN APPROVED DRAWING  
PRELIMINARY DESIGN

CONTRACT SHEET No.

LIGHT RAIL TRANSIT SYSTEM  
LINE SECTION CBD-2

COMMERCE STATION AIRFLOW  
EMERGENCY VENTILATION DIAGRAM

## CONTRACT

DWG No.

IC 7 - 0003

EV

[illegible]

D R A F T

THIS IN-PROGRESS DRAWING IS RELEASED  
FOR REVIEW UNDER THE AUTHORITY OF:  
JERRY STEVEN CASEY, P.E. NO. 65588  
ON 10/30/2020  
HNTB CORPORATION  
TBE FIRM NO. F-420  
IT SHALL BE UPDATED AND  
CONFIRMED UPON COMPLETION OF  
SUBSURFACE INVESTIGATIONS

# HNTB

HNTB Corporation  
The HNTB Companies  
Engineers Architects Planners  
TBPE Firm Registration No. 420



DART PROJECT



SCALE	NTS
DRAWN	S. PARAYIL
DESIGNED	S. PARAYIL
CHECKED	S. CASSADY
IN CHARGE	J. CASEY
DATE	30 OCT 2020






## Appendix E. CFD Simulation Results

DRAFT






APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 3r2)




Example Graphic – A1




APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 3r2)




APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 3r2)




APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 3r2)




APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 3r2)



APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 3r2)




APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 3r2)






APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2.5M ABOVE PLATFORM LEVEL (Case No.4)




Example Graphic – B1


APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2.5M ABOVE PLATFORM LEVEL (Case No.4)




APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2.5M ABOVE PLATFORM LEVEL (Case No.4)




APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2.5M ABOVE PLATFORM LEVEL (Case No.4)




200123\_DART\_D2\_Commerce\_Station\_r9\_4  
Apr 05, 2020  
ANSYS Fluent Release 19.2 (3d, pbns, spe, ske, transient)  
Contours of visblyt-igt-ref-m (Time=9.0000e+01)  
HNTB Corporation



200123\_DART\_D2\_Commerce\_Station\_r9\_4  
Apr 05, 2020  
ANSYS Fluent Release 19.2 (3d, pbns, spe, ske, transient)  
Contours of visblyt-igt-ref-m (Time=1.0000e+02)  
HNTB Corporation





200123\_DART\_D2\_Commerce\_Station\_r9\_4  
Apr 05, 2020  
ANSYS Fluent Release 19.2 (3d, pbns, spe, ske, transient)  
Contours of visblyt-igt-ref-m (Time=1.1000e+02)  
HNTB Corporation





200123\_DART\_D2\_Commerce\_Station\_r9\_4  
Apr 05, 2020  
ANSYS Fluent Release 19.2 (3d, pbns, spe, ske, transient)  
Contours of visblyt-igt-ref-m (Time=1.2000e+02)  
HNTB Corporation

APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2.5M ABOVE PLATFORM LEVEL (Case No.4)





APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2.5M ABOVE PLATFORM LEVEL (Case No.4)








APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2.5M ABOVE PLATFORM LEVEL (Case No.4)



APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2.5M ABOVE PLATFORM LEVEL (Case No.4)




APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2.5M ABOVE PLATFORM LEVEL (Case No.4)




Contours of visblyt-igt-ref-m (Time=2.9000e+02)  
HNTB Corporation

200123\_DART\_D2\_Commerce\_Station\_r9\_4  
Apr 05, 2020  
ANSYS Fluent Release 19.2 (3d, pbns, spe, ske, transient)




Contours of visblyt-igt-ref-m (Time=3.0000e+02)  
HNTB Corporation

200123\_DART\_D2\_Commerce\_Station\_r9\_4  
Apr 05, 2020  
ANSYS Fluent Release 19.2 (3d, pbns, spe, ske, transient)



Contours of visblyt-igt-ref-m (Time=3.1000e+02)  
HNTB Corporation



200123\_DART\_D2\_Commerce\_Station\_r9\_4  
Apr 05, 2020  
ANSYS Fluent Release 19.2 (3d, pbns, spe, ske, transient)





Contours of visblyt-igt-ref-m (Time=3.2000e+02)  
HNTB Corporation

200123\_DART\_D2\_Commerce\_Station\_r9\_4  
Apr 05, 2020  
ANSYS Fluent Release 19.2 (3d, pbns, spe, ske, transient)

APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2.5M ABOVE PLATFORM LEVEL (Case No.4)





APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2.5M ABOVE PLATFORM LEVEL (Case No.4)






APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2.5M ABOVE PLATFORM LEVEL (Case No.4)




APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 5)




Example Graphic – C1


APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 5)



APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 5)




APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 5)







APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 5)




APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 5)




APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 5)



APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 5)




APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 5)







APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 5)




APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 5)




APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 5)



APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 5)



APPENDIX  
DART D2 Preliminary Ventilation Report  
CFD RESULTS OF SMOKE VISIBILITY 2M ABOVE PLATFORM LEVEL (Case No. 5)





## Appendix F. Critical Velocity Calculation

DRAFT





Made By: SSP Date: 2/14/2020 Job Number: 61144  
 Sheet No.: 1  
 File Name:

\\seaw00\jobs2\61144\Redbook\08\_TechProd\20%\_Cncpt\_Dsgn\_Rpt\dart SES\cr\_vel\_ for DART D

PROJECT NAME: DART D2

#### Vehicle Tunnel Smoke Backlayering Calculation

#### Tunnel Area

#### 14.69 MW LOAD

Description	Value	Variable	Units			
Critical Velocity Constant	0.606	K1	none			
Grade Factor	1.0	K2	none			
Acceleration of Gravity	32.2	g	ft/(sec^2)			
Height of the tunnel	16	H	ft			
Fire Energy Load	13941	Q	Btu/sec	949	14.69	MW
Specific heat of air	0.24	Cp	Btu/(lb*F)			
Perpendicular area of tunnel	285	A	ft^2			
Initial guess Average temp of fire site gases	1200	Tf	R			
Average Temperature of approach air	539.33	Ti	R	459	80.33	DEG F from CFD model (300K)
Density of air	0.0735	rho	lb/(ft^3)			From engineering toolbox

#### Iteration constant

Units	R	FPS	R
Iterative Solution			
	Tf	Vc	Tfit
	1200	6.407576	972.0937
	1086.047	6.624049	957.951
	1021.999	6.759493	949.5629
	985.7809	6.841199	944.6633
	965.2221	6.889382	941.8286
	953.5253	6.91741	940.1977
	946.8615	6.933583	939.2626
	943.0621	6.942873	938.7275
	940.8948	6.948194	938.4216
	939.6582	6.951238	938.2469
	938.9525	6.952977	938.1471
	938.5498	6.95397	938.0901
	938.32	6.954538	938.0576
	938.1888	6.954861	938.0391
	938.1139	6.955046	938.0285
	938.0712	6.955152	938.0224
	938.0468	6.955212	938.019
	938.0329	6.955246	938.017
	938.0249	6.955266	938.0159
	938.0204	6.955277	938.0152
	938.0178	6.955283	938.0149
	938.0163	6.955287	938.0146
	938.0155	6.955289	938.0145
	938.015	6.95529	938.0145
	938.0147	6.955291	938.0144
	938.0146	6.955291	938.0144
			459 479.01 DEG F

Velocity for smoke backlayering 417.32 FPM

#### REQUIRED AIRFLOW DOWN TUNNEL TO PREVENT SMOKE BACKLAYERING

118,935 CFM

#### TOTAL REQUIRED SMOKE EVACUATION FLOW

237871

Flow splits to each fan plant 118,935

Considering Fire Site Temperatures Flow Capacity Expansion 5.963082

Assume duct smoke cooling and air mixture cools effective temperature of smoke inlet into ventilation system

Fire Site Temperature Expansion Factor 3 356806.5


$$V_c = K_1 K_g \left( \frac{gHQ}{\rho C_p A T_f} \right)^{1/3} \quad (D.1)$$

$$T_f = \left( \frac{Q}{\rho C_p A V_c} \right) + T$$


where:

- $V_c$  = critical velocity [m/sec (fpm)]
- $K_1$  = 0.606 (Froude number factor,  $Fr^{-1/3}$ )
- $K_g$  = grade factor (*see Figure D.1*)
- $g$  = acceleration caused by gravity [m/sec<sup>2</sup> (ft/sec<sup>2</sup>)]
- $H$  = height of duct or tunnel at the fire site [m (ft)]
- $Q$  = heat fire is adding directly to air at the fire site [MW (Btu/sec)]
- $\rho$  = average density of the approach (upstream) air [kg/m<sup>3</sup> (lb/ft<sup>3</sup>)]
- $C_p$  = specific heat of air [kJ/kg K (Btu/lb°R)]
- $A$  = area perpendicular to the flow [m<sup>2</sup> (ft<sup>2</sup>)]
- $T_f$  = average temperature of the fire site gases [K (°R)]
- $T$  = temperature of the approach air [K (°R)]

Figure D.1 provides the grade factor for ( $K_g$ ) in equation D.1.




**FIGURE D.1 Grade Factor for Determining Critical Velocity.**



WESTBOUND  
(SECTION LOOKING WEST)

TBM RUNNING TUNNEL WITH PRECAST SEGMENTAL LINER  
TYPICAL SECTION - OPTION 1 WESTBOUND TUNNEL AS SHOWN  
SCALE: 3/8" = 1'-0" EASTBOUND TUNNEL OPP HAND



EASTBOUND  
(SECTION LOOKING EAST)

TBM RUNNING TUNNEL WITH CAST-IN-PLACE CONCRETE LINER  
 TYPICAL SECTION - OPTION 2 EASTBOUND TUNNEL AS SHOWN  
 SCALE:  $\frac{3}{8}$ " = 1'-0" WESTBOUND TUNNEL OPP HAND

NOTES:

1. FOR STRUCTURAL GENERAL NOTES, SEE DRAWING NO. GC3-0001.
2. FOR STRUCTURAL SYMBOLS AND ABBREVIATIONS, SEE DWG No. GC3-0002.
3. STATIC AND DYNAMIC ENVELOPES SHOWN ARE FOR CURVED TRACK, R=300', WITH SUPERELEVATION: 1.5".
4. MINIMUM CLEARANCE BETWEEN TOP OF RAIL AND BOTTOM OF CATENARY CABLE SHALL BE 14-FEET.
5. SIGNALS, SYSTEMS EQUIPMENT, RAIL AND FACILITIES SHOWN ON THESE CROSS-SECTIONS ARE INCOMPLETE AND FOR ILLUSTRATION ONLY. SEE RELEVANT DISCIPLINE DRAWINGS FOR DETAILS.

SCALE (IN FEET)



0 1 2 4

D R A F T

CONCEPTUAL DESIGN PENDING  
RAIL/FACILITY SYSTEMS AND  
TUNNEL/STATION VENTILATION INPUT,  
AND ADDITIONAL SITE SPECIFIC DATA

NOT FOR CONSTRUCTION  
NOT AN APPROVED DRAWING  
ADVANCED CONCEPTUAL DESIGN

CONTRACT SHEET No.

LIGHT RAIL TRANSIT SYSTEM  
LINE SECTION CBD-2

TBM RUNNING TUNNEL - SINGLE BORE  
TYPICAL SECTION  
OPTIONS 1 & 2

CONTRACT	DWG No. SC8-0001	REV
----------	------------------	-----

[illegible]

THIS DOCUMENT IS RELEASED  
FOR THE PURPOSE OF REVIEW UNDER THE  
AUTHORITY OF:  
CHARLES A. STONE, P.E. NO. 133866  
ON 03/06/2020  
HNTB CORPORATION  
TBEF FIRM NO. F-420  
IT IS NOT TO BE USED FOR CONSTRUCTION  
BIDDING OR PERMIT PURPOSES.


# HNTB

HNTB Corporation  
The HNTB Companies  
Engineers Architects Planners  
TBPE Firm Registration No. 420



**DART PROJECT**



SCALE	$\frac{3}{8}" = 1' - 0"$
DRAWN	B. WHITESIDE
DESIGNED	C. MOON
CHECKED	R. MANUELYAN
IN CHARGE	C. STONE
DATE	06 MAR 2020
	

# Pass Fail Criteria

Case No	Tunnel Configuration	Height of Tunnel	Tunnel Cross Sectional Area	Fire load	Derived Values [4]			Notes
					Critical Vel. [1]	Critical Vel. + 10% F.S. [2]	Critical Airflow	
		(ft)	(sq. Ft)	(MW)	(fpm)	(fpm)	(kcfm)	
1	Tunnel track	16	285	14.9	417	459	131	1
2	Station Track	16	230	14.9	437	481	111	1
1	Tunnel track	16	175	14.9	417	459	80	5
2	Station Track	16	120	14.9	437	481	58	5

## Notes:

- [1] Critical velocity for full area is used
- [2] Added 10% factor of safety per BFS Criteria - Mechanical Line Sections, page 12 of 18
- [3] Fourde number used for critical velocity calculation is 0.85 per interpolation based on a fire load of 15 MW.
- [4] Fourde number used for critical velocity calculation is 0.606 per interpolation based on a fire load of 15 MW.
- [5] Annular area = tunnel area minus train area




## Appendix G. VENTILATION SPACE PROOFING

DRAFT



SCALE (IN FEET)



0 20 40

GENERAL NOTES:

1. TVS DUCT SIZING AND SUBGRADE STRUCTURE VOLUMES ARE ESTABLISHED ON THE BASIS OF TRANSIT SYSTEM INSTALLATION WITH FULL HEIGHT PLATFORM SCREEN DOORS.

**DRAFT**  
CONCEPTUAL DESIGN PENDING  
FURTHER RAIL/FACILITY SYSTEMS  
INPUT AND ADDITIONAL  
SUBSURFACE INVESTIGATIONS

NOT FOR CONSTRUCTION  
NOT AN APPROVED DRAWING  
PRELIMINARY DESIGN

CONTRACT SHEET No.	OF
--------------------	----

LIGHT RAIL TRANSIT SYSTEM  
LINE SECTION CBD-2  
COMMERCE STATION  
OVERALL LOWER LEVEL  
MECHANICAL SPACE PROOFING  
FLOOR PLAN

CONTRACT	DWG No.	REV
	MC2-3410	

CM - LOWER LEVEL OVERALL MECHANICAL SPACE PROOFING PLAN

SCALE: 1" = 40'

$$\frac{1}{-}$$

D R A F T

THIS IN-PROGRESS DRAWING IS RELEASED  
FOR REVIEW UNDER THE AUTHORITY OF:  
JERRY STEVEN CASEY, P.E. NO. 65588

ON 10/30/2020

HNTB CORPORATION  
TBPE FIRM NO. F-420

IT SHALL BE UPDATED AND  
CONFIRMED UPON COMPLETION OF  
SUBSURFACE INVESTIGATIONS

# HNTB

HNTB Corporation  
The HNTB Companies  
Engineers Architects Planners  
TBPE Firm Registration No.420




DART PROJECT



SCALE	1" = 40' - 0"
DRAWN	B. WHITESIDE
DESIGNED	T. TRAN
CHECKED	S. CASSADY
IN CHARGE	J. CASEY
DATE	30 OCT 2020

[illegible]






THIS IN-PROGRESS DRAWING IS RELEASED  
FOR REVIEW UNDER THE AUTHORITY OF:  
JERRY STEVEN CASEY, P.E. NO. 65588  
ON 10/30/2020  
HNTB CORPORATION  
TBPE FIRM NO. F-420  
IT SHALL BE UPDATED AND  
CONFIRMED UPON COMPLETION OF  
SUBSURFACE INVESTIGATIONS

HNTB Corporation  
The HNTB Companies  
Engineers Architects Planners  
TBPE Firm Registration No.420



SCALE	1" = 40' - 0"
DRAWN	B. WHITESIDE
DESIGNED	T. TRAN
CHECKED	S. CASSADY
IN CHARGE	J. CASEY
DATE	30 OCT 2020




NOT FOR CONSTRUCTION  
NOT AN APPROVED DRAWING  
PRELIMINARY DESIGN

CONTRACT SHEET No. \_\_\_\_\_ OF \_\_\_\_\_

LIGHT RAIL TRANSIT SYSTEM  
LINE SECTION CBD-2  
COMMERCE STATION  
OVERALL PLATFORM LEVEL  
MECHANICAL SPACE PROOFING  
FLOOR PLAN

CONTRACT	DWG No.	REV
	MC2-3510	

[illegible]



GENERAL NOTES:

1. TYS DUCT SIZING AND AND SUBGRADE STRUCTURE VOLUMES ARE ESTABLISHED ON THE BASIS OF TRANSIT SYSTEM INSTALLATION WITH FULL HEIGHT PLATFORM SCREEN DOORS.

**DRAFT**  
CONCEPTUAL DESIGN PENDING  
FURTHER RAIL/FACILITY SYSTEMS  
INPUT AND ADDITIONAL  
SUBSURFACE INVESTIGATIONS

NOT FOR CONSTRUCTION  
NOT AN APPROVED DRAWING  
PRELIMINARY DESIGN

CONTRACT SHEET No.

LIGHT RAIL TRANSIT SYSTEM  
LINE SECTION CBD-2

COMMERCE STATION  
MECHANICAL SPACE PROOFING  
CROSS SECTIONS

## CONTRACT

DWG No.

IC5-3011

REV

[illegible]

DRAFT

THIS IN-PROGRESS DRAWING IS RELEASED  
FOR REVIEW UNDER THE AUTHORITY OF:  
JERRY STEVEN CASEY, P.E. NO. 65588

ON 10/30/2020  
HNIB CORPORATION  
TBPE FIRM NO. F-420

IT SHALL BE UPDATED AND  
CONFIRMED UPON COMPLETION OF  
SUBSURFACE INVESTIGATIONS


# HNTB


HNTB Corporation  
The HNTB Companies  
Engineers Architects Planners  
TBPE Firm Registration No.420



DART PROJECT



SCALE	$\frac{1}{8}" = 1' - 0"$
DRAWN	B. WHITESIDE
DESIGNED	T. TRAN
CHECKED	S. CASSADY
IN CHARGE	J. CASEY
DATE	30 OCT 2020
	



**DRAFT**  
CONCEPTUAL DESIGN PENDING  
FURTHER RAIL/FACILITY SYSTEMS  
INPUT AND ADDITIONAL  
SUBSURFACE INVESTIGATIONS

NOT FOR CONSTRUCTION  
NOT AN APPROVED DRAWING  
PRELIMINARY DESIGN

CONTRACT SHEET No.

LIGHT RAIL TRANSIT SYSTEM  
LINE SECTION CBD-2

COMMERCE STATION  
MECHANICAL SPACE PROOFING  
CROSS SECTIONS

CONTRACT	
----------	--

DWG No.
---------

MC5-3018

REV

CM - MECHANICAL SPACE PROOFING CROSS SECTIONS

SCALE: 1" = 1/8"

1  
MC2-3410  
MC2-3510

D R A F T

THIS IN-PROGRESS DRAWING IS RELEASED  
FOR REVIEW UNDER THE AUTHORITY OF:  
JERRY STEVEN CASEY, P.E. NO. 65588  
ON 10/30/2020  
HNIB CORPORATION  
TBPE FIRM NO. F-420  
IT SHALL BE UPDATED AND  
CONFIRMED UPON COMPLETION OF  
SUBSURFACE INVESTIGATIONS

# HNTB

HNTB Corporation  
The HNTB Companies  
Engineers Architects Planners  
TBPE Firm Registration No.420



**DART PROJECT**



SCALE	1/4"=1'-0"
DRAWN	B. WHITESIDE
DESIGNED	T. TRAN
CHECKED	S. CASSADY
IN CHARGE	J. CASEY
DATE	30 OCT 2020

[illegible]